

Locations Not Measured



This report lists Component locations that have not had a condition assessment since a specified date

The top portion summarizes <u>Total</u> <u>Locations</u>, <u>Locations on a Task</u>, <u>Locations Measured</u>, and <u>Locations Not Measured</u>

The lower portion* lists locations not measured by <u>Unit</u>, <u>Function</u>, <u>Asset</u>, <u>Asset Component</u>, <u>Criticality</u>, <u>Date Last Measured</u>, and <u>Task</u>.

The "Locate in Tree" button is in the left-most column.

				Location Totals				
tal Locations on a Task			tions on a Task	Locations Measured		Locations Not Measured		
2793			2291	2193	2193		98	
Loca	ations Not Mea	sured						
nly the	top 100 results app	ear in this web report. The Excél	export will contain all results.				Filter:	
	Unit	Function	Asset	Component	Criticality	Date Last Measured	Tasks (Technology)	
h	INDIAN CREEK PLANT	AEROBIC DIGESTION BLOWERS	BLOWER, AEROBIC DIGESTER #2	015631 - MOTOR, AC	0	9/6/2017 7:49:57 AM	MCA OFFLINE-ICTP-AEROBIC DIGESTION- ANNUAL (Electrical - Offline) MCA ONLINE-ICTP-AEROBIC DIGESTION-9 MONTH (Electrical - Online) IR MECH-ICTP-AEROBIC DIGESTION-ANNUA (Thermography) VIB-ICTP-AEROBIC DIGESTION-QUARTERLY (Vibration - Route)	
ф	INDIAN CREEK PLANT	SEC SETTLING	SEC CLARIFIER #3	013229 - COLLECTOR, ROTARY	0	2/22/2017 7:44:44 AM	IR MECH-ICTP-SEC SETTLING-ANNUAL (Thermography)	
dı	INDIAN CREEK PLANT	SLUDGE THICKENING	DIGESTER SLUDGE PUMP	015644 - PUMP, CENTRIFUGAL	0	4/24/2014 12:00:00 AM	VIB-ICTP-SLUDGE THICKENING-QUARTERLY (Vibration - Route)	
ф	LITTLE MIAMI PLANT	4-MILE PUMP STATION	EXCESS FLOW PUMP #2	001422 - PUMP, CENTRIFUGAL	0	3/30/2017 2:28:58 PM	UE-LMTP-4-MILE PUMP STATION- QUARTERLY-RCM (Ultrasonic Testing) IR MECH-LMTP-4 MILE-ANNUAL (Thermography) VIB-LMTP-4 MILE-QUARTERLY-RCM (Vibration - Route)	

*Only the first 100 results appear in the web report. You may export a complete report in Excel format by clicking the "Export" button in the upper right of the page.



Locating the Report











